



ELLIOTT COMPANY
901 North Fourth Street
Jeannette, PA 15644-1474
Phone: 724-600-8993
Fax: 724-600-8442
E-mail: thalchak@elliott-turbo.com

Tristano J. Halchak Jr.
Manager – Health, Safety & Environmental

19 July 2013

Director
Air Protection Division
1650 Arch Street
Philadelphia, PA, 19103

RECEIVED
JUL 30 2013
Air Protection Division
(3AP10)

RE: Elliott Turbomachinery Company, Inc.
Initial Notification – Area Source RICE MACT (40 CFR Part 63 Subpart ZZZZ)

Dear Sir/Madam:

Elliot Turbomachinery Company, Inc. (Elliott) operates a turbine manufacturing facility in Jeannette, Pennsylvania. The facility operates a natural gas-fired spark-ignition generator which is used to provide back-up power during the turbine testing operations.

As per 40 CFR §63.6645 and §63.9(b), Elliott is submitting the attached initial notification letter for applicability to the requirements of National Emission Standards for Hazardous Air Pollutants (NESHAP) for Reciprocating Internal Combustion Engines (RICE) codified at 40 CFR Part 63 Subpart ZZZZ. The facility shall comply with all applicable requirements of the regulation on or before 19 October 2013.

Please contact me at (724) 600-8993 or thalchak@elliott-turbo.com, if you have any questions regarding this notification letter.

Sincerely,

Tristano J. Halchak, Jr.
Manager
Health, Safety & Environment
Elliott Group

cc: Cynthia Chamberlain, Elliott Group
Anand Yegnan, ERM

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines

40 CFR part 63, subpart **ZZZZ**

☒ Yes, I am subject to 40 CFR part 63, subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 3563

Compliance Date: ☒ Existing (before 6/12/2006) source: Oct 19, 2013

☐ New/reconstructed (on or after 6/12/2006) source: Upon initial startup

Note: The Oct 19, 2013 compliance date for existing sources applies to the following engine types:

- Existing stationary spark ignition (SI) RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary SI RICE located at an area source of HAP emissions

Company name: **ELLIOTT TURBO MACH INC.**

Facility name (if different): **ELLIOTT TURBO MACH INC.**

Facility (physical location) address: **901 N 4th Street**

Jeannette, PA, 15644

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: **SAME AS ABOVE**

Owner/company address: **SAME AS ABOVE**